

**QUESTIONS & ANSWERS**  
**SITE VISIT – REPAIR POOL AWNING**  
**SOLICITATION SPM07013Q0068**

1. Will you be supplying a revised copy of page 26 ATTACHMENT #2 as the original is clearly not for this job.

Answer: See revised Attachment #2 attached

2. Do you require all the existing fence post be extended including the intermediate smaller 1 inch square fencing?

Answer: Only the intermediate walk between the pool area and BBQ

3. Please confirm what size 1/2 or 3/4 inch EMT conduit and the type of LED lights

Answer: 3/4

4. Please confirm that the ground level light near the path be removed along with the removal and connecting back the sprinkler outlet.

Answer: Yes

5. Please confirm that the two electric circuits are one 220 volts and one 110 volts.

Answer: Yes one water hearted and one power recepticals.

6. Please confirm the 12 x 18 foot concrete slab is to be extended to the curved path.

Answer: Yes extend the new pad to the sidewalk

7. Please confirm the installation of a 6 inch wide half-moon shaped trench running alongside the existing support wall.

Answer: Yes it should run along the walk and around the corner into new corner drain.

8. Please confirm that you only require 3no 4 x 4 x 1/4 steel posts to be installed on the existing concrete.

Answer: Yes only three new poles inside the pool area and three outside the pool area.

9. Please confirm if the whole of the pool concrete needs repairing and repainting.

Answer: Yes with same type or material the color can be similar.

10. Please confirm that the new concrete slab has the same finish and color as the rest of the pool surround.

Answer: Yes

11. How high is the ceiling?

Answer: 10' sloping to 9 1/2'